



BID #2015-03 - FY 2016 CITY OF LEON VALLEY DETENTION AREA 2
SEPTEMBER 14, 2015 - 10:00 A.M.
NON-MANDATORY PRE-BID MEETING
QUESTIONS/ANSWERS

- Q. Is any demolition needed?
A. No, just excavation.
- Q. Are there restricted work times?
A. Per City Ordinance, contractors may only work Monday through Friday from 7:00 a.m. to 6:00 p.m. (except in cases of emergency).
- Q. Is a Stormwater Plan required? Will we need to book a plan to the state?
A. The project involves less than 5 acres so no plan is required, just a permit.
- Q. Is there any silt fencing?
A. Yes, some.
- Q. Is there just one (1) rock berm?
A. Yes.
- Q. Is soil stabilization required?
A. Yes, hydroseeding.
- Q. What type of matting is required and how much?
A. Vendors choice and 80% growth.
- Q. There are three (3) different wage rates listed. Which one do we use?
A. NISD's wage rates.